

TO WHOM IT MAY CONCERN


Memo No:- 04(A) Date:- 19/02/2024

This is to certify that our inspection team has inspected DAV Public School (TISCO), Noamundi District-West Singhbhum, Jharkhand on 16-02-2024 and found satisfactory of the following things.

1. Sanitary Conditions
2. Drinking water
3. Fire Safety

They have sufficient equipments for the above said points. They have enough fire extinguisher in working condition, toilet, urinal and taps etc. They keep the whole campus neat and clean. The school has also water cooler facility for safe drinking for students.




Block Development Officer
प्रखण्ड विकास पदाधिकारी
Noamundi, Singhbhum (W),
नोवामुण्डी, पठ सिंहभूम
Jharkhand.

सेवा में ,

प्रखण्ड विकास पदाधिकारी

नोवामुंडी ।

विषय :- डी.ए.वी. स्कूल नोवामुंडी संबंधित स्वच्छता , पेयजल एवं अग्नि सुरक्षा की जांच प्रतिवेदन के संबंध में ।

महाशय ,

उपयुक्त विषय के संबंध में कहना है कि कार्यालय आदेशनुसार दिनांक 16-02-2024 को जांच में निम्नलिखित पाया गया :-

क्र.सं.	जांच का प्रकार	अभियुक्ति
1	शौचालय	कुल 7 शौचालय यूनिट पाया गया,जिसमें 3 यूनिट बालकों,3 यूनिट बालिकाओं एवं 1 यूनिट स्टाफ के लिए है ।
2	पेयजल व्यवस्था	हैन्डवॉश यूनिट एवं वाटर कूलर की सुविधा उपलब्ध किया हुआ पाया गया ।
3	अग्नि सुरक्षा	अग्निशामक की सुविधा पाया गया ।

अतः दिए गए उपरोक्त जांच की वर्तमान स्थिति सुरक्षा एवं स्वच्छता में सही पाया गया ।

अनुलग्नक :- फोटोग्राफ संलग्न ।

Pengke
17/02/24

कनिया अभियंता

नोवामुंडी ।

विश्वासभाजन

Pitish
17/02/2024


सहायक अभियंता

नोवामुंडी ।

Self Attested
PBN

PRINCIPAL
DAV PUBLIC SCHOOL (TISCO)
Noamundi, Singhbhum
West Jharkhand-833217
Aff No 3430056

Pitish
18/4/24
CHAIRMAN
D.A.V. PUBLIC SCHOOL (TISCO)
NOAMUNDI-833 217
SINGHBHUM WEST (JHARKHAND)



District Level Water Testing Laboratory
Office of the Executive Engineer (DW&SD)
Near Adityapur Thana, Jamshedpur-831013
Email: dlwtl.jamshedpur@gmail.com



TC-11294

Report No:	JSR/2024/45	Memo no:	113/28-03-2024
Issue To/ Name and Address of customer:	D.A.V Public School (TISCO) Noamundi, West Singhbhum, Jharkhand	Sample code:	240328GWND09
Sample Type;	Drinking water	Sample collected by	Customer
Sample receive on:	28/03/2024	Sample Description:	Boring water
Test start on :	28/03/2024	Date completion on:	28/03/2024
ULR:	T C 1 1 2 9 4 2 4	0 0 0 0 0	0 0 4 5 F

Test Result


Sl. No.	Tested Parameter	Unit	Results	Method	Specification as per IS – 10500-2012 (Second Revision)	
					Acceptable Limit	Permissible Limit (Absence of Alternate source)
1	pH, at 25°C	-	7.10	APHA 24th Ed.2023-4500-H B, (Electrometric method)	6.5 – 8.5	No relaxation
2	Turbidity	NTU max	1.50	APHA 24 th Ed.2023-2130 B, (Nephelometric method)	1	5
3	Alkalinity as CaCO ₃	mg/L max	200	APHA 24 th Ed.2023-2320 B, (Titration method)	200	600
4	Calcium as (Ca)	mg/L max	86.4	APHA 23 rd Ed 2017-3500 Ca B, (EDTA Titration method)	75	200
5	Magnesium as Mg	mg/L max	27.84	APHA 24 th Ed 2023-3500-Mg B, (Calculation method)	30	100
6	Hardness as CaCO ₃	mg/L max	332	APHA 24 th Ed 2023-2340 C, (EDTA Titration method)	200	600
7	Fluoride as (F)	mg/L max	0.75	APHA 24 th Ed 2023-4500 F C, (Ion selective electrode method)	1.0	1.50
8	Total Dissolved Solids at 180°C	mg/L max	400	APHA 24 th Ed.2023-2540 C, Total Dissolved Solids Dried at 180°C	500	2000
9	Chloride (cl)	mg/L max	63.52	APHA 24 th Ed.2023-4500 Cl B, (Argentometric method)	250	1000
10	Colour	Hazen	01	IS:3025, (Part-4)	5	15
11	Taste	-	Agreeable	IS:3025, (Part-5)	Agreeable	-
12	Odour	-	Agreeable	IS: 3025, (Part-7)	Agreeable	-

Remarks:- This result is according to BIS limit.

Specific contractual notes: -

- ◆ The results listed refer only to the tested sample and applicable parameter.
- ◆ This report, in full or in part, shall not be used for advertising or as evidence in any court of law.
- ◆ This report can not be reproduced, except when in full, without the written permission of the Lab In-charge
- ◆ Tested Sample shall be retained up to Seven Days from the date of issue of the certificate.
- ◆ The liability of the laboratory is limited to the invoiced amount.
- ◆ All disputes are subjected to the Jamshedpur Jurisdiction.
- ◆ NOTE:- BDL=Below Detection Limit / DL=Detection Limit.
- ◆ Sample is not drawn by laboratories.

Reviewed by :  28/03/24
(Technical Manager)


Supriya Kumari
Authorised Signatory
(Quality Manager)

Technical Manager

Quality Manager

District Level Water Testing Laboratory
D.W. & S. Division, Jamshedpur

District Level Water Testing Laboratory
D.W. & S. Division, Jamshedpur

Self Attested


PRINCIPAL
DAV PUBLIC SCHOOL (TISCO)

Noamundi, Singhbhum
West Jharkhand-833217
Aff. No 3430056


CHAIRMAN

D.A.V. PUBLIC SCHOOL (TISCO)
NOAMUNDI-833 217
SINGHBHUM WEST (JHARKHAND)



Requisition Slip

Doc No.: JSR-DLWTL-QP-4-F03
Issue No.: 01
Revision No.: 00
Date :

(Drinking / Ground and Surface Water Samples)

Name of Customer	DAV Public School	Date	28/03/24
Address	Noamundi West Singhbhum	Sample condition	Good
Contact Person	Santoshi Keshri	Contact no.	8200479178

Scope of Work

Physico-Chemical Parameters

S.no	Parameters	Method	Quantity
01	Taste	APHA 23 rd Edition 2017	1 litre
02	Colour		
03	Odour		
04	pH		
05	Turbidity		
06	Fluoride		
07	Total Hardness		
08	Calcium		
09	Magnesium		
10	TDS		
11	Chloride		
12	Total Alkalinity		
Bacteriological Parameter			
13	Total Coliform	APHA 23 rd Edition 2017	
14	Fecal Coliform		
Payment Term			
1	Payment mode	offline	500/-

[Signature]
Signature

Technical Manager

[Signature]
Signature/Date

Customer

Technical Manager

District Level Water Testing Laboratory
B.W. & S. Division, Jamshedpur

self attested
PPH
PRINCIPAL

DAV PUBLIC SCHOOL (TISCO)
Noamundi, Singhbhum
West Jharkhand-833217
Aff. No.3430056

District Level Water Testing Laboratory
Jamshedpur, Jharkhand

[Signature]
CHAIRMAN

D.A.V. PUBLIC SCHOOL (TISCO)
NOAMUNDI-833 217
SINGHBHUM WEST (JHARKHAND)

ओ३म
टाटा आयरन एण्ड स्टील के सहयोग से
दयानन्द ऐंग्लोवैदिक कॉलेज
प्रबन्धकर्तृ समिति, नई दिल्ली द्वारा
संचालित शिक्षण संस्थान



D.A.V. PUBLIC SCHOOL (TISCO)
NOAMUNDI WEST SINGHBHUM
JHARKHAND - 833217
☎ : 7482842101
E-mail : dav_noamundi@yahoo.co.in,
dav.noamundi@gmail.com

A co-educational Senior Secondary English Medium School • Affiliated to CBSE Delhi • Affiliation No. : 3430056 • School No. 66253

Ref No. DAV/NMD/CBSE AFFILIATION FILE/23-24/417

Date: 27.03.2024

To,
The Executive Engineer,
Water and Sanitary Department,
Adityapur,
Distt. -Saraikela-Kharsawan .

Sub: Testing of Water Sample for Portability.

Respected Sir,

This is the sample of water for the purpose of portability. Kindly check it's portability and provide us Lab. report and certificate in a separate format attached here with for official purposes.

Looking forward to your avid cooperation and oblige.

Thanking you,

With regards,

Yours faithfully,

PBH
(P. K. Bhuyan)

Principal
PRINCIPAL

DAV PUBLIC SCHOOL (TISCO)
Noamundi, Singhbhum
West Jharkhand-833217
Aff. No.3430056

Received by
Manisha Tanti
28/03/24

Jharkhand Zone A - Shri O. P. Mishra Assistant Regional Officer, D.A.V. Public Schools, (Jharkhand Zone - A), NIT Campus, Adityapur

SELF ATTESTED
PBH

PRINCIPAL
DAV PUBLIC SCHOOL (TISCO)
Noamundi, Singhbhum
West Jharkhand-833217
Aff. No. 3430056

PBH
18/4/24
CHAIRMAN
D.A.V. PUBLIC SCHOOL (TISCO)
NOAMUNDI-833 217
SINGHBHUM WEST (JHARKHAND)